



NEILSON RESEARCH CORPORATION

Environmental Testing Laboratory

12/21/2016

Dale Giovannetti
Central Point Sch. Dist/Sams Valley Elem
300 Ash St.
Central Point, OR 97502

TEL: (541) 494-6924

FAX

RE: District Office - Lead

Order No.: 1612573

Dear Dale Giovannetti:

Neilson Research Corporation received 4 sample(s) on 12/14/2016 for the analyses presented in the following report.

The results relate only to the parameters tested or to the sample as received by the laboratory. This report shall not be reproduced except in full, without the written approval of Neilson Research Corporation. If you have any questions regarding these test results, please feel free to call.

Sincerely,
Neilson Research Corporation

Alec C Smith
Project Manager

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Project: District Office - Lead
Lab Order: 1612573

Date: 21-Dec-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Sample Information: District Office - Lead

Lab Order: 1612573

Received Date: 12/14/2016 3:08:00 PM

Reported Date: 12/21/2016 2:57:41 PM

Lab ID: 1612573-01

Collection Date: 12/14/2016 6:17:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26891

Source: City Water

Sample Location: 3rd Flr Mens RR Sink

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: BAR	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.0280	CF*	0.0001	mg/L	1	12/15/2016	A	

Lab ID: 1612573-02

Collection Date: 12/14/2016 6:19:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26841

Source: City Water

Sample Location: 1st Flr Mens RR Sink

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: BAR	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.0152		0.0001	mg/L	1	12/15/2016	A	

Lab ID: 1612573-03

Collection Date: 12/14/2016 6:21:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26833

Source: City Water

Sample Location: 1st Flr Womens RR Sink

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: BAR	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.101	CF*	0.0001	mg/L	1	12/20/2016	A	

Lab ID: 1612573-04

Collection Date: 12/14/2016 7:15:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #26849

Source: City Water

Sample Location: Hanby N21 Sink #3

Trace Metals by EPA 200.8 ICP-MS						Dilution	Analyst: BAR	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited	
Lead	0.00455		0.0001	mg/L	1	12/15/2016	A	

Qualifiers:

* Value exceeds Maximum Contaminant Level
E Value above quantitation range
J Analyte detected below quantitation limits
S Spike Recovery outside accepted recovery limits

B Analyte detected in the associated Method Blank
H Holding times for preparation or analysis exceeded
ND Not Detected at the Minimum Reporting Limit

Neilson Research Corporation
DATA FLAGS

B	Analyte detected in the associated method blank.
BA	BOD Alternative Calculation: The initial results performed by Standard Methods did not fall within parameters of the Standard Methods calculation. An alternate approved calculation was performed using the HACH method and the value reported is an estimated concentration.
C	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria. See Case Narrative.
C1	Sample(s) does not meet NELAP/ORELAP sample acceptance criteria for temperature.
CF	Results confirmed by re-analysis.
CU	Cleanup performed as specified by method.
D1	The diesel elution pattern for the sample is not typical.
D2	The sample appears to be a heavier hydrocarbon range than diesel.
D3	The sample appears to be a lighter hydrocarbon range than diesel.
D4	Detected hydrocarbons do not have pattern and range consistent with typical petroleum products and may be due to biogenic interference.
D5	Detected hydrocarbons in the diesel range appear to be weathered diesel.
E	Estimated value.
ER	Elevated reporting limit due to matrix. Report limits (MDLs, MRLs & PQLs) are adjusted based on variations in sample preparation amounts, analytical dilutions, and percent solids, where applicable.
FC	Fecal Coliforms: Sample(s) received past 40 CFR Part 136 specified holding time. Results reported as estimated values.
G1	The gasoline elution pattern for the sample is not typical.
G2	The sample appears to be a heavier hydrocarbon range than gasoline.
G3	The sample appears to be a lighter hydrocarbon range than gasoline.
G4	Detected hydrocarbons in the gasoline range appear to be weathered gasoline.
HP	Sample re-analysis performed outside of method specified holding time.
HR	Sample received outside of method specified holding time.
HS	Sample analyzed for volatile organics contained headspace.
HT	At the client's request, the sample was analyzed outside of method specified holding time.
H	Analysis performed outside of method specified holding time.
J	Analyte detected below the Minimum Reporting Limit (MRL) and above the Method Detection Limit (MDL). The J flag result is an estimated value and the user should be aware that this data is of limited reliability.
MI	Surrogate or Matrix Spike recovery is out of control limits due to matrix interference. Sample results may be biased.
N	See Case Narrative on page 2 of report.
Q	Closing continuing calibration verification (CCV) or laboratory control sample (LCS) exceeded high recovery limits, but associated samples are non-detect and the sample results are not affected. Data meets EPA/NELAP requirements.
R	Relative percent difference (RPD) is outside of the accepted recovery limits.
R1	Relative percent difference (RPD) is outside of the accepted recovery limits. However, analyses are not controlled on RPD values for sample concentrations that are less than the reporting limit.
R3	The relative percent difference (RPD) and/or percent recovery for the duplicate (DUP) or matrix spike (MS)/matrix spike duplicate (MSD) cannot be accurately calculated due to the concentration of analyte already present in the sample.
R4	Duplicate analysis failed due to result being at or near method reporting limit.
S	Surrogate and/or matrix spike recovery is outside of the accepted recovery limits. Sample results may be biased.
S1	Surrogate or matrix spike recovery is outside of control limits due to dilution necessary for analysis.
SC	Sub-contracted to another laboratory for analysis.
SP	Sample(s) were not collected per EPA Method 5035A protocols. The results are considered minimum values.
T	Toxicity Characteristic Leaching Procedure – Sample submitted contained < 0.5% solids. If the waste contains <0.5% dry solids, the liquid portion of the waste, after filtration, is defined as the TCLP extract.
#	Value exceeds regulatory level for TCLP contaminant.
X1	The motor oil elution pattern for the sample is not typical.
X2	The sample appears to be a heavier hydrocarbon range than motor oil.
X3	The sample appears to be a lighter hydrocarbon range than motor oil.
*	Value exceeds Maximum Contaminant Level or is outside the acceptable range.

NRC SOP QA-1104/AD-3100
Revision 3
Effective Date: 6/3/16

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Work Order: 1612573
Project: District Office - Lead

ANALYTICAL QC SUMMARY REPORT

BatchID: 37266

Sample ID MB-37266	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 12/15/2016	RunNo: 92004						
Client ID: ZZZZZ	Batch ID: 37266	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 12/15/2016	SeqNo: 1397096						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000100

Sample ID LCS-37266	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 12/15/2016	RunNo: 92004						
Client ID: ZZZZZ	Batch ID: 37266	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 12/15/2016	SeqNo: 1397097						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09323 0.000100 0.1 0 93.2 85 115

Sample ID 1612550-01AMS	SampType: MS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 12/15/2016	RunNo: 92004						
Client ID: ZZZZZ	Batch ID: 37266	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 12/15/2016	SeqNo: 1397099						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09642 0.000100 0.1 0.001163 95.3 70 130

Sample ID 1612550-01AMSD	SampType: MSD	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 12/15/2016	RunNo: 92004						
Client ID: ZZZZZ	Batch ID: 37266	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 12/15/2016	SeqNo: 1397100						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09556 0.000100 0.1 0.001163 94.4 70 130 0.09642 0.896 20

Qualifiers: E Value above quantitation range H Holding times for preparation or analysis exceeded J Analyte detected below quantitation limits
 ND Not Detected at the Minimum Reporting Limit R RPD outside accepted recovery limits S Spike Recovery outside accepted recovery limits

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Work Order: 1612573
Project: District Office - Lead

ANALYTICAL QC SUMMARY REPORT

BatchID: 37292

Sample ID MB-37292	SampType: MBLK	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 12/19/2016	RunNo: 92055						
Client ID: ZZZZZ	Batch ID: 37292	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 12/19/2016	SeqNo: 1397862						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead ND 0.000100

Sample ID LCS-37292	SampType: LCS	TestCode: ICPMS_200.8	Units: mg/L	Prep Date: 12/19/2016	RunNo: 92055						
Client ID: ZZZZZ	Batch ID: 37292	TestNo: EPA 200.8	(EPA 200.8)	Analysis Date: 12/19/2016	SeqNo: 1397863						
Analyte	Result	MRL	SPK value	SPK Ref Val	%REC	LowLimit	HighLimit	RPD Ref Val	%RPD	RPDLimit	Qual

Lead 0.09430 0.000100 0.1 0 94.3 85 115

Qualifiers: E Value above quantitation range
 ND Not Detected at the Minimum Reporting Limit

H Holding times for preparation or analysis exceeded
 R RPD outside accepted recovery limits

J Analyte detected below quantitation limits
 S Spike Recovery outside accepted recovery limits



Environmental Testing Laboratory
 245 South Grape Street • Medford, OR 97501
 (541) 770-5678 fax (541) 770-2901

This Chain of Custody is a LEGAL DOCUMENT and must be filled out accurately.

Page ___ of ___

Chain of Custody Record

Section A Required Client Information

Company: C.P. School District #6
 Address: 300 Ash Street
Central Point OR 97502
 Email: _____
 Phone: 541-494-6521 Fax: _____
 Collected By (Print): Jeff Carr
 Collected By (Sign): [Signature]
 Email Report: Yes No Mail Report: Yes No
 Fax Report: Yes No

Section B Required Project Information

Project Name: OSWICK OFFICE
 Project Number: _____
 Report To: _____
 Copy To: _____

Section C Invoice Information

Attention: _____
 Company Name: _____
 Address: _____
 P.O. # _____

Section D Rush Status (Subject to Scheduling)

Standard 10-14 Days
 5 Business Days (50% surcharge)
 3 Business Days (75% surcharge)
 24 - 48 hours (100% surcharge)
 Other: _____
 Authorized: Yes No

Section E Sample Information

Sample ID	Comp/Grab	Matrix*	Date Collected	Time Collected	No. of Containers	Analysis Requested
3rd Floor Mens RR Sink	26891	DW	12-14-16	6:17AM	1	Lead
1st Floor Mens RR Sink	26841	DW	12-14-16	6:19AM	1	
1st Floor Womens RR Sink	26833	DW	12-14-16	6:21AM	1	
Handy Wash Sink #3	26849	DW	12-14-16	7:15	1	

Section F Relinquish/Receive

Relinquished By: [Signature] Sign _____
 Received By: _____
 Relinquished By: _____
 Received By: _____
 Relinquished By: _____
 Received By: _____
 Relinquished By: _____
 Received By: _____
 Relinquished By: _____
 Received By: _____

Section G Lab Use Only

Temp: AMB
 4°C +/- 2°C: Yes No
 Received on ice: Yes No
 Number of Bottles Received: 4
 pH Checked: NA
 COC Seals Intact: Yes No NA
 Field Blank Included: Yes No

Payment: Invoice Cash VISA, M/C Check # _____
 Received Via: UPS FedEx Other Hand
 Amount: _____