

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

CLIENT: Central Point Sch. Dist/Sams Valley Elem
Project: District Office - Lead & Coppers
Lab Order: 1611275

Date: 21-Nov-16

CASE NARRATIVE

The analyses were performed according to the guidelines in the Neilson Research Corporation Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

Neilson Research Corporation certifies that this report is in compliance with the requirements of NELAP. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

Lab Order: **1611275**

300 Ash St.

Received Date: **11/7/2016 8:50:00 AM**

Central Point, OR 97502

Reported Date: **11/21/2016 11:39:12 AM**

Sample Information: District Office - Lead & Coppers

Lab ID: 1611275-01

Collection Date: 11/5/2016 10:47:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27645

Source: City Water

Sample Location: 1st Flr Womens RR

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Copper	0.835		0.000515	mg/L	1	11/16/2016	A
Lead	0.0285	CF*	0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611275-02

Collection Date: 11/5/2016 10:45:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27268

Source: City Water

Sample Location: 1st Flr Mens RR

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Copper	0.526		0.000515	mg/L	1	11/16/2016	A
Lead	0.0256	CF*	0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611275-03

Collection Date: 11/5/2016 10:46:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27627

Source: City Water

Sample Location: Tech Dep Sink

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Copper	0.462		0.000515	mg/L	1	11/16/2016	A
Lead	0.0355	CF*	0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611275-04

Collection Date: 11/5/2016 10:50:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27222

Source: City Water

Sample Location: 2nd Flr Womens RR

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Copper	0.657		0.000515	mg/L	1	11/16/2016	A
Lead	0.00879		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611275-05

Collection Date: 11/5/2016 10:50:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27640

Source: City Water

Sample Location: 2nd Flr Mens RR

Trace Metals by EPA 200.8 ICP-MS					Dilution	Analyst: OML	NELAP
Analyses	Result	Qual	MRL	Units	Factor	Date Analyzed	Accredited
Copper	0.553		0.000515	mg/L	1	11/16/2016	A
Lead	0.00986		0.000103	mg/L	1	11/16/2016	A

Qualifiers:

- | | |
|--|---|
| <ul style="list-style-type: none"> * Value exceeds Maximum Contaminant Level E Value above quantitation range J Analyte detected below quantitation limits S Spike Recovery outside accepted recovery limits | <ul style="list-style-type: none"> B Analyte detected in the associated Method Blank H Holding times for preparation or analysis exceeded ND Not Detected at the Minimum Reporting Limit |
|--|---|

Neilson Research Corporation

245 South Grape Street, Medford, Oregon 97501 541-770-5678 Fax 541-770-2901

Analysis Report

ORELAP 100016
EPA OR00028

Central Point Sch. Dist/Sams Valley Ele

300 Ash St.

Central Point, OR 97502

Lab Order: **1611275**

Received Date: **11/7/2016 8:50:00 AM**

Reported Date: **11/21/2016 11:39:12 AM**

Sample Information: District Office - Lead & Coppers

Lab ID: 1611275-06

Collection Date: 11/5/2016 10:57:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27215

Source: City Water

Sample Location: 3rd Flr Staff Sink

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.652		0.000515	mg/L	1	11/16/2016	A
Lead	0.00164		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611275-07

Collection Date: 11/5/2016 10:53:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27643

Source: City Water

Sample Location: 3rd Flr Womens RR

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.573		0.000515	mg/L	1	11/16/2016	A
Lead	0.00890		0.000103	mg/L	1	11/16/2016	A

Lab ID: 1611275-08

Collection Date: 11/5/2016 10:55:00 AM

Matrix: DRINKING WATER

Client Sample ID: Bottle #27644

Source: City Water

Sample Location: 3rd Flr Mens RR

Trace Metals by EPA 200.8 ICP-MS

Analyses	Result	Qual	MRL	Units	Dilution Factor	Analyst: OML Date Analyzed	NELAP Accredited
Copper	0.793		0.000515	mg/L	1	11/16/2016	A
Lead	0.0286	CF*	0.000103	mg/L	1	11/16/2016	A

Qualifiers:

- | | |
|---|--|
| * Value exceeds Maximum Contaminant Level | B Analyte detected in the associated Method Blank |
| E Value above quantitation range | H Holding times for preparation or analysis exceeded |
| J Analyte detected below quantitation limits | ND Not Detected at the Minimum Reporting Limit |
| S Spike Recovery outside accepted recovery limits | |